

NORTH TEXAS MUNICIPAL WATER DISTRICT - Tawakoni
Water Analysis
May-2023

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	119	185		500		1000
Silica (SiO ₂)	2.82	2.29				
Iron (Fe)	<0.200	<0.200		0.3		0.3
Calcium (Ca)	28.9	45.9				
Magnesium (Mg)	3.06	3.20				
Sodium (Na)	11.2	17.2				
Potassium (K)	4.24	4.25				
Sulfate (SO ₄)	12.7	69.9		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	0.306	0.382	10		10	
Chloride (Cl)	8.0	15.9		250		300
Fluoride (F)	0.172	0.619	4.0	2.0	4	2.0
Phosphates (PO ₄)	0.0600	<0.0100				
	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)
Total Alkalinity	88.7 *	116.8 *				
Total Hardness	94.0	122				
Langelier Index		0.180				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00175	0.00131	0.01		0.01	
Barium (Ba)	0.0771	0.0829	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.00129	0.0170	1.3	1	1.3	1.0
Iron (Fe)	<0.200	<0.200		0.3		0.3
Lead (Pb)	<0.000500	0.000707	0.015		0.015	
Manganese (Mn)	0.0322	<0.0250		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00152	0.00551				
Selenium (Se)	<0.00100	0.00149	0.05		0.05	
Silver (Ag)	<0.00050	0.00067		0.10		0.1
Zinc (Zn)	<0.00250	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.65 *	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.50	8.00 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	218	333				
Turbidity (NTU)	2.6 *	0.04 *	0.3		0.3	
Threshold Odor Number	<1.00	<1.00				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.