

**** NORTH TEXAS MUNICIPAL WATER DISTRICT - Tawakoni**
Water Analysis
Nov-2021

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	135	192		500		1000
Silica (SiO ₂)	4.62	4.48				
Iron (Fe)	0.285	0.280		0.3		0.3
Calcium (Ca)	26.9	43.2				
Magnesium (Mg)	2.73	2.75				
Sodium (Na)	10.7	17.7				
Potassium (K)	4.28	4.25				
Sulfate (SO ₄)	9.98	54.7		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	0.264	0.269	10		10	
Chloride (Cl)	6.5	13.7		250		300
Fluoride (F)	0.172	0.430	4.0	2.0	4	2.0
Phosphates (PO ₄)	0.0670	<0.0100				
	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)
Total Alkalinity	84.6 *	67.5 *				
Total Hardness	82.0	106				
Langelier Index		-0.2590				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00191	<0.00050	0.01		0.01	
Barium (Ba)	0.0774	0.0465	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	<0.00100	0.00897	1.3	1	1.3	1.0
Iron (Fe)	0.285	0.280		0.3		0.3
Lead (Pb)	<0.000500	<0.000500	0.015		0.015	
Manganese (Mn)	0.0406	0.00187		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00184	0.00442				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	<0.00250	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.54 *	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.50	7.90 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	201	294				
Turbidity (NTU)	5.4 *	0.06 *	0.3		0.3	
Threshold Odor Number	33	<1				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.