

<u>Mineral Analysis</u>	<u>Raw</u>	<u>Treated</u>	<u>Standards</u>			
			<u>EPA</u> <u>Primary</u>	<u>EPA</u> <u>Secondary</u>	<u>TCEQ</u> <u>Primary</u>	<u>TCEQ</u> <u>Secondary</u>
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	128	198		500		1000
Silica (SiO ₂)	4.77	4.95				
Iron (Fe)	<0.200	<0.200		0.3		0.3
Calcium (Ca)	22.5	41.3				
Magnesium (Mg)	2.41	2.73				
Sodium (Na)	7.44	14.6				
Potassium (K)	3.86	3.87				
Sulfate (SO ₄)	7.59	55.7		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	0.203	0.486	10		10	
Chloride (Cl)	4.8	15.9		250		300
Fluoride (F)	0.162	0.229	4.0	2.0	4	2.0
Phosphates (PO ₄)	0.0690	<0.0100				
	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)
Total Alkalinity	76.7 *	66.5 *				
Total Hardness	77.0	105				
Langelier Index		0.0170				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00380	0.00065	0.01		0.01	
Barium (Ba)	0.0751	0.0543	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	<0.00100	0.0256	1.3	1	1.3	1.0
Iron (Fe)	<0.200	<0.200		0.3		0.3
Lead (Pb)	<0.000500	<0.000500	0.015		0.015	
Manganese (Mn)	0.0352	0.00979		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00143	0.00413				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	<0.00250	0.00253		5		5

Other Analysis

Chlorine Residual (mg/L)	--	2.98 *	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.50	8.00 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	190	315				
Turbidity (NTU)	4.2 *	0.06 *	0.3		0.3	
Threshold Odor Number	8.0	3.0				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.