

NORTH TEXAS MUNICIPAL WATER DISTRICT - Bonham
Water Analysis
Jun-2022

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	97.0	205		500		1000
Silica (SiO ₂)	3.68	3.36				
Iron (Fe)	0.905	<0.200		0.3		0.3
Calcium (Ca)	16.1	48.1				
Magnesium (Mg)	2.21	2.28				
Sodium (Na)	4.51	13.8				
Potassium (K)	4.11	3.89				
Sulfate (SO ₄)	2.65	67.6		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	<0.0500	0.163	10		10	
Chloride (Cl)	4.35	16.9		250		300
Fluoride (F)	0.128	0.405	4.0	2.0	4	2.0
Phosphates (PO ₄)	0.148	<0.0100				

	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)
Total Alkalinity	68.4 *	78.7 *				
Total Hardness	62.0	130				
Langelier Index	--	-0.042				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00533	<0.00050	0.01		0.01	
Barium (Ba)	0.0613	0.0631	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.00281	0.00119	1.3	1	1.3	1.0
Iron (Fe)	0.905	<0.200		0.3		0.3
Lead (Pb)	0.000514	<0.000500	0.015		0.015	
Manganese (Mn)	0.557	<0.0250		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00138	0.00532				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	<0.00250	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	2.92	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.20 *	7.95 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	126	323				
Turbidity (NTU)	18.8 *	0.08 *	0.3		0.3	
Threshold Odor Number	<1.00	<1.00				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.