

NORTH TEXAS MUNICIPAL WATER DISTRICT - Bonham
Water Analysis
Mar-2019

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	82.0	177		500		1000
Silica (SiO ₂)	<2.00	<2.00				
Iron (Fe)	1.58	0.357		0.3		0.3
Calcium (Ca)	12.0	47.2				
Magnesium (Mg)	1.45	2.04				
Sodium (Na)	3.62	10.1				
Potassium (K)	2.31	2.51				
Sulfate (SO ₄)	3.05	64.1		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	<0.0500	0.0630	10		10	
Chloride (Cl)	5.18	11.3		250		300
Fluoride (F)	0.0600	0.549	4.0	2.0	4	2.0
Phosphates (PO ₄)	0.178	<0.0100				
	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)
Total Alkalinity	43.7 *	66.3 *				
Total Hardness	34.8	119				
Langelier Index	--	--				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00118	<0.00050	0.01		0.01	
Barium (Ba)	0.0477	0.0371	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.00347	0.00280	1.3	1	1.3	1.0
Iron (Fe)	1.58	0.357		0.3		0.3
Lead (Pb)	0.00106	<0.000500	0.015		0.015	
Manganese (Mn)	0.0652	0.00266		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00218	0.00508				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	0.00504	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	2.74	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.04 *	7.81 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	86.6	298				
Turbidity (NTU)	41.0 *	0.06 *	0.3		0.3	
Threshold Odor Number	33.0	1.0				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.