

NORTH TEXAS MUNICIPAL WATER DISTRICT - Bonham
Water Analysis
Sep-2021

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	148	248		500		1000
Silica (SiO ₂)	7.16	6.19				
Iron (Fe)	0.485	0.354		0.3		0.3
Calcium (Ca)	17.3	52.1				
Magnesium (Mg)	2.46	2.71				
Sodium (Na)	24.9	14.3				
Potassium (K)	4.06	3.87				
Sulfate (SO ₄)	1.83	80.9		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	<0.0500	0.217	10		10	
Chloride (Cl)	19.8	17.3		250		300
Fluoride (F)	0.103	0.128	4.0	2.0	4	2.0
Phosphates (PO ₄)	0.144	<0.0100				

	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)
Total Alkalinity	71.9 *	83.0 *				
Total Hardness	58.0	136				
Langelier Index	--	-0.087				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00669	0.00089	0.01		0.01	
Barium (Ba)	0.103	0.0716	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.121	0.00371	1.3	1	1.3	1.0
Iron (Fe)	0.485	0.354		0.3		0.3
Lead (Pb)	<0.000500	<0.000500	0.015		0.015	
Manganese (Mn)	0.254	0.00507		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00107	0.00509				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	0.00291	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	2.81	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.60 *	7.93 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	202	372				
Turbidity (NTU)	14.7 *	0.08 *	0.3		0.3	
Threshold Odor Number	3	<1				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.