

NORTH TEXAS MUNICIPAL WATER DISTRICT - Bonham
Water Analysis
Sep-2022

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	118	236		500		1000
Silica (SiO ₂)	6.72	6.34				
Iron (Fe)	0.343	<0.200		0.3		0.3
Calcium (Ca)	18.8	48.0				
Magnesium (Mg)	2.49	2.58				
Sodium (Na)	4.92	17.2				
Potassium (K)	4.45	4.37				
Sulfate (SO ₄)	1.59	67.3		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	<0.0500	0.213	10		10	
Chloride (Cl)	4.74	23.3		250		300
Fluoride (F)	0.133	0.498	4.0	2.0	4	2.0
Phosphates (PO ₄)	0.112	0.0210				
	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)
Total Alkalinity	77.7 *	75.0 *				
Total Hardness	68.0	120				
Langelier Index	--	-0.065				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00704	0.00129	0.01		0.01	
Barium (Ba)	0.0880	0.0617	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.00284	0.00626	1.3	1	1.3	1.0
Iron (Fe)	0.343	<0.200		0.3		0.3
Lead (Pb)	0.000586	<0.000500	0.015		0.015	
Manganese (Mn)	0.172	<0.0250		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00120	0.00438				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	<0.00250	0.00273		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.10	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.57 *	7.98 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	146	356				
Turbidity (NTU)	14.3 *	0.09 *	0.3		0.3	
Threshold Odor Number	<1.00	<1.00				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.