

NORTH TEXAS MUNICIPAL WATER DISTRICT - Bonham
Water Analysis
Aug-2022

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	150	225		500		1000
Silica (SiO ₂)	6.24	5.68				
Iron (Fe)	0.387	<0.200		0.3		0.3
Calcium (Ca)	19.8	48.1				
Magnesium (Mg)	2.65	2.44				
Sodium (Na)	17.5	15.6				
Potassium (K)	4.68	4.09				
Sulfate (SO ₄)	1.98	62.6		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	<0.0500	0.179	10		10	
Chloride (Cl)	21.4	21.5		250		300
Fluoride (F)	0.128	0.639	4.0	2.0	4	2.0
Phosphates (PO ₄)	0.131	0.0150				

	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)
Total Alkalinity	76.6 *	86.0 *				
Total Hardness	64.0	194				
Langelier Index	--	0.224				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00694	0.00101	0.01		0.01	
Barium (Ba)	0.157	0.0565	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.114	0.00180	1.3	1	1.3	1.0
Iron (Fe)	0.387	<0.200		0.3		0.3
Lead (Pb)	<0.000500	<0.000500	0.015		0.015	
Manganese (Mn)	0.274	<0.0250		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00147	0.00419				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	0.00063	<0.00050		0.10		0.1
Zinc (Zn)	0.00274	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	2.93	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.55 *	8.01 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	206	336				
Turbidity (NTU)	17.3 *	0.07 *	0.3		0.3	
Threshold Odor Number	<1.00	<1.00				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.