

NORTH TEXAS MUNICIPAL WATER DISTRICT - Bonham (revised)
Water Analysis
Feb-2023

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	115	186		500		1000
Silica (SiO ₂)	2.84	<2.00				
Iron (Fe)	1.72	<0.200		0.3		0.3
Calcium (Ca)	14.7	52.4				
Magnesium (Mg)	2.06	2.15				
Sodium (Na)	5.67	11.8				
Potassium (K)	3.69	3.48				
Sulfate (SO ₄)	3.55	71.4		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	0.200	0.233	10		10	
Chloride (Cl)	7.27	14.2		250		300
Fluoride (F)	0.0820	0.159	4.0	2.0	4	2.0
Phosphates (PO ₄)	0.168	<0.0100				

	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)
Total Alkalinity	62.6 *	74.6 *				
Total Hardness	68.0	124				
Langelier Index	--	0.26				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00150	<0.00050	0.01		0.01	
Barium (Ba)	0.0581	0.0451	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.152	0.00459	1.3	1	1.3	1.0
Iron (Fe)	1.72	<0.200		0.3		0.3
Lead (Pb)	0.00144	<0.000500	0.015		0.015	
Manganese (Mn)	0.0719	<0.0250		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00262	0.00555				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	0.00836	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.03	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.66 *	7.87 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	114	305				
Turbidity (NTU)	36.1 *	0.06 *	0.3		0.3	
Threshold Odor Number	1.00	1.00				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.