

NTMWD Wylie Water Treatment Plants

Monthly Water Quality Data For November 2025

Coliform Bacteria

| Maximum Contaminant Level Goal | Total Coliform Maximum Contaminant Level | Highest No. of Positive | Fecal Coliform or E. Coli Maximum Contaminant Level | Total No. of Positive E. Coli or Fecal Coliform Samples | Violation | Likely Source of Contamination |
|--------------------------------|--|-------------------------|---|---|-----------|---------------------------------------|
| 0 | 1 positive monthly sample | 0 | 0 | 0 | No | Naturally present in the environment. |

NOTE: Reported monthly tests found no fecal coliform bacteria. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present.

Regulated Contaminants

| Disinfectants and Disinfection By-Products | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|---|-----------------|--------------------------------|--------------------------------|-----------------------|-----|-------|-----------|--|
| Total Haloacetic Acids (HAA5) | Nov 2025 | 17.1 | 16.3 - 17.1 | No goal for the total | 60 | ppb | No | By-product of drinking water disinfection. |
| Total Trihalomethanes (TTHM) | Nov 2025 | 38.8 | 32.3 - 38.8 | No goal for the total | 80 | ppb | No | By-product of drinking water disinfection. |
| NOTE: Monthly independent lab testing results for disinfection by-products (DBPs) in NTMWD transmission system. Sampling locations represent a cross-section of average water ages in the NTMWD transmission system. As a wholesale water provider with less than 500 direct customers, TCEQ only requires one sample annually for Disinfection By Products (DBPs) compliance testing. In addition to TCEQ required testing on the NTMWD regional system, over 300 samples of water initially treated by NTMWD are tested for DBPs each year within the city/local water systems to comply with TCEQ regulations. | | | | | | | | |
| Bromate | Nov 2025 | Levels lower than detect level | Levels lower than detect level | 5 | 10 | ppb | No | By-product of drinking water ozonation. |

NOTE: For Bromate, compliance is based on the running annual average.

| Inorganic Contaminants | Collection Date | Raw (Source Water) | Treated (Finished Water) | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--------------------------------|-----------------|--------------------------------|--------------------------------|------|-----|-------|-----------|--|
| Arsenic | Nov 2025 | 2.11 - 3.69 | 0.623 - 1.07 | 0 | 10 | ppb | No | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes. |
| Barium | Nov 2025 | 0.0416 - 0.167 | 0.0506 - 0.0611 | 2 | 2 | ppm | No | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits. |
| Cadmium | Nov 2025 | Levels lower than detect level | Levels lower than detect level | 5 | 5 | ppb | No | Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints. |
| Chromium | Nov 2025 | Levels lower than detect level | Levels lower than detect level | 100 | 100 | ppb | No | Discharge from steel and pulp mills; erosion of natural deposits. |
| Fluoride | Nov 2025 | 0.200 - 0.388 | 0.350 - 0.875 | 4 | 4 | ppm | No | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories. |
| Mercury | Nov 2025 | 0.11 - 0.11 | Levels lower than detect level | 2 | 2 | ppb | No | Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland. |
| Nitrate (measured as Nitrogen) | Nov 2025 | 0.100 - 0.324 | 0.229 - 0.335 | 10 | 10 | ppm | No | Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits. |
| Selenium | Nov 2025 | 1.2 - 1.73 | Levels lower than detect level | 50 | 50 | ppb | No | Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines. |

Nitrate Advisory: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

Turbidity

| | Limit (Treatment Technique) | Level Detected | Violation | Likely Source of Contamination |
|---|-----------------------------|----------------|-----------|--------------------------------|
| Highest single measurement | 1 NTU | 0.28 | No | Soil runoff. |
| Lowest monthly percentage (%) meeting limit | 0.3 NTU | 100% | No | Soil runoff. |

NOTE: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration.

Maximum Residual Disinfectant Level

| Disinfectant Type | Collection Date | Average Level | Range of Levels Detected | MRDL | MRDLG | Units | Source of Chemical |
|---------------------------------|-----------------|---------------|--------------------------|------|-------|-------|--|
| Chlorine Residual (Chloramines) | Nov 2025 | 2.99 | 1.82 - 3.90 | 4.00 | <4.0 | ppm | Disinfectant used to control microbes. |
| Chlorine Dioxide | Nov 2025 | 0.01 | 0.00 - 0.18 | 0.80 | 0.80 | ppm | Disinfectant. |
| Chlorite | Nov 2025 | 0.12 | 0.00 - 0.47 | 1.00 | N/A | ppm | Disinfectant. |

NOTE: Water providers are required to maintain a minimum chlorine disinfection residual level of 0.5 parts per million (ppm) for systems disinfecting with chloramines and an annual average chlorine disinfection residual level of between 0.5 (ppm) and 4 parts per million (ppm).

Total Organic Carbon

NOTE: The percentage of Total Organic Carbon (TOC) Removal was measured through the month, and the system met all TOC Removal requirements set.

NTMWD Wylie Water Treatment Plants

Monthly Water Quality Data For November 2025

Lead and Copper

| Lead and Copper | Collection Date | Raw (Source Water) | Treated (Finished Water) | Action Level | Units | Violation | Likely Source of Contamination |
|-----------------|-----------------|--------------------------------|--------------------------------|--------------|-------|-----------|---|
| Lead | Nov 2025 | Levels lower than detect level | Levels lower than detect level | 15 | ppb | No | Corrosion of household plumbing systems; erosion of natural deposits. |
| Copper | Nov 2025 | 0.0012 - 0.0117 | 0.0011 - 0.0018 | 1.3 | ppm | No | Erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing systems. |

NOTE: Monthly independent lab testing results for lead and copper at the entry point to the NTMWD Transmission System.

ADDITIONAL HEALTH INFORMATION FOR LEAD: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The NTMWD is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Secondary and Other Constituents Not Regulated

| Contaminants | Collection Date | Raw (Source Water) | Treated (Finished Water) | Units | Secondary Standards | Likely Source of Contamination |
|---------------------------------------|-----------------|--------------------------------|--------------------------------|-------|-------------------------|---|
| Calcium | Nov 2025 | 30.0 - 77.8 | 37.0 - 40.3 | ppm | No Standard Established | Abundant naturally occurring element. |
| Chloride | Nov 2025 | 27.4 - 226 | 66.2 - 76.2 | ppm | 300 | Abundant naturally occurring element; used in water purification; by-product of oil field activity. |
| Corrosivity Index | Nov 2025 | Not Applicable | (-) 0.49 - (+) 0.31 | units | No Standard Established | Values greater than zero are scale forming, whereas values less than zero are more corrosive. |
| Iron | Nov 2025 | 0.211 - 0.355 | Levels lower than detect level | ppm | 0.3 | Erosion of natural deposits; iron or steel water delivery equipment or facilities. |
| Magnesium | Nov 2025 | 5.19 - 25.4 | 8.11 - 9.29 | ppm | No Standard Established | Abundant naturally occurring element. |
| Manganese | Nov 2025 | 0.030 - 0.066 | Levels lower than detect level | ppm | 0.05 | Abundant naturally occurring element. |
| Nickel | Nov 2025 | 0.0027 - 0.0048 | 0.0060 - 0.0073 | ppm | No Standard Established | Erosion of natural deposits. |
| pH | Nov 2025 | 7.7 - 8.9 | 7.5 - 8.7 | SU | >7 | Measure of corrosivity of water. |
| Potassium | Nov 2025 | 5.57 - 5.94 | 5.54 - 5.81 | ppm | No Standard Established | Abundant naturally occurring element. |
| Silver | Nov 2025 | Levels lower than detect level | Levels lower than detect level | ppm | 0.1 | Erosion of natural deposits. |
| Sodium | Nov 2025 | 27.9 - 135 | 62.1 - 71.2 | ppm | No Standard Established | Erosion of natural deposits; by-product of oil field activity. |
| Sulfate | Nov 2025 | 34.0 - 156 | 109 - 121 | ppm | 300 | Naturally occurring; common industrial by-product; by-product of oil field activity. |
| Total Alkalinity as CaCO ₃ | Nov 2025 | 87.0 - 145 | 64.3 - 93.0 | ppm | No Standard Established | Naturally occurring soluble mineral salts. |
| Total Dissolved Solids | Nov 2025 | 178 - 740 | 332 - 386 | ppm | 500 - 1000 | Total dissolved mineral constituents in water. |
| Total Hardness as CaCO ₃ | Nov 2025 | 93.9 - 480 | 127 - 140 | ppm | No Standard Established | Naturally occurring calcium. |
| Zinc | Nov 2025 | 0.0026 - 0.0033 | 0.0048 - 0.0067 | ppm | 5 | Moderately abundant naturally occurring element used in the metal industry. |

Taste and Odor Compounds

| Analytes | Collection Date | Raw (Source Water) Range of Levels Detected | Treated (Finished Water) Range of Levels Detected | Units | Secondary Standards | Likely Source of Contamination |
|--------------------|-----------------|---|---|-------|-------------------------|---|
| Geosmin | Nov 2025 | 6.4 - 12 | 2.6 - 7.7 | ppt | No Standard Established | Compound naturally found in lakes. Causes earthy, dirt-like odor. |
| 2-Methylisoborneol | Nov 2025 | 3.5 - 5.0 | 2.0 - 2.2 | ppt | No Standard Established | Compound naturally found in lakes. Causes musty, wet mulch like odor. |

Note: Geosmin and 2-Methylisoborneol, produced by cyanobacteria, filamentous bacteria and other organisms, are found in surface water sources and are the most commonly reported taste and odor compounds. They have earthy-musty odors which are difficult to remove by conventional water treatment processes. The human nose is extremely sensitive to these compounds. The threshold for detection for Geosmin is approximately 15 parts per trillion (ng/L) and for MIB is approximately 10 ppt. However, variations in human perception of taste and odor, means that some people may detect Geosmin in concentrations as low as 5 ppt and MIB in concentrations as low as 2 ppt - which is roughly equivalent to a teaspoon of Geosmin into 200 Olympic-sized swimming pools.