

NORTH TEXAS MUNICIPAL WATER DISTRICT - Wylie**Water Analysis****May-2023**

Mineral Analysis	Standards					
	Raw	Treated	EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	253	309		500		1000
Silica (SiO ₂)	6.86	6.34				
Iron (Fe)	0.243	<0.200		0.3		0.3
Calcium (Ca)	52.2	52.0				
Magnesium (Mg)	6.09	6.48				
Sodium (Na)	30.9	51.1				
Potassium (K)	6.39	6.51				
Sulfate (SO ₄)	45.5	102		250		
Nitrite (NO ₂)	<0.0500	<0.0500	1		1	
Nitrate (NO ₃)	0.333	0.447	10		10	
Chloride (Cl)	31.2	41.3		250		300
Fluoride (F)	0.345	0.619 *	4.0	2.0	4.0	2.0
Phosphates (PO ₄)	0.131	<0.0100				

	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)
Total Alkalinity	117 *	103 *				
Total Hardness	148	150				
Langelier Index		0.200				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00235	0.00076	0.01		0.01	
Barium (Ba)	0.0569	0.0504	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.166	0.00666	1.3	1	1.3	1.0
Iron (Fe)	0.243	<0.200		0.3		0.3
Lead (Pb)	<0.000500	<0.000500	0.015		0.015	
Manganese (Mn)	0.0301	<0.0250		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00373	0.00602				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.000500	<0.000500		0.10		0.1
Zinc (Zn)	0.0186	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.50 *	4.0		4.0	
Total coliform (Present / Absent)	--	A *	A		A	
pH (Standard Units) @ 25°C	8.13 *	7.96 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	437 *	543 *				
Turbidity (NTU)	11.8 *	0.166 *	0.3		0.3	
Threshold Odor Number	1.43	<1.00				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses.